

Certificate of Compliance

Issued to:	Custom Design Group
Apparatus:	Moulded Plug and Socket sets
Models:	FAA Style 1 plug with FAA style 8 socket FAA Style 5 plug with FAA style 12 socket FAA Style 4 plug with FAA style 11 socket
No. of Samples Tested:	One of each
Relevant Specification used as Basis of Tests:	BS EN 60529: 1992 Inc Amendments 1 and 2 to IP68 (2 metres water depth for 24 hours)

This is to certify that, on the basis of the tests undertaken, the above items were tested and considered to comply with the requirements for IP68 as specified in the above standard and by the client to be 2 metres water depth for a duration of 24 hours. For specific details of the tests see Intertek Report No 06021272 dated July 2006.

Signed: Signature.....
A Colgate
Engineer

Signed: Signature.....
A Van Daele
Business Stream Manager

Date of issue: July 2006



Custom Design Group
Units 212-214
Springvale Industrial Estate
Cwmbran
South Wales
NP44 5BJ

Serial No: 06-5343
Reference No: 06021272

Intertek Testing & Certification Ltd

Intertek House, Cleeve Road, Leatherhead, Surrey KT22 7SB
Telephone: +44 (0)1372 370900 Fax: +44 (0)1372 370999 Web: www.uk.intertek-etlsemko.com

Registered No. 3272281 Registered Office: 25 Savile Row, London W1S 2ES

For Terms & Conditions please see reverse

Certificate of Compliance

Issued to:	Custom Design Group
Apparatus:	Moulded Plug and Socket sets
Models:	3 Way Locking Style 5 Way Locking Style
No. of Samples Tested:	One of each
Relevant Specification used as Basis of Tests:	BS EN 60529: 1992 Inc Amendments 1 and 2 to IP68 (2 metres water depth for 24 hours)

This is to certify that, on the basis of the tests undertaken, the above items were tested and considered to comply with the requirements for IP68 as specified in the above standard and by the client to be 2 metres water depth for a duration of 24 hours. For specific details of the tests see Intertek Report No 06021272 dated July 2006.

Signed: Signature.....
A Colgate
Engineer

Signed: Signature.....
A Van Daele
Business Stream Manager

Date of issue: July 2006



Custom Design Group
Units 212-214
Springvale Industrial Estate
Cwmbran
South Wales
NP44 5BJ

Serial No: 06-5342
Reference No: 06021272

Intertek Testing & Certification Ltd

Intertek House, Cleeve Road, Leatherhead, Surrey KT22 7SB
Telephone: +44 (0)1372 370900 Fax: +44 (0)1372 370999 Web: www.uk.intertek-etlsemko.com

Registered No. 3272281 Registered Office: 25 Savile Row, London W1S 2ES

For Terms & Conditions please see reverse